



Ref. Certif. No.

SE-90979

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit-breakers for overcurrent protection

Name and address of the applicant

Zhejiang ETEK Electrical Technology Co., Ltd.
No. 288 Wei17th Road, Yueqing Economic Development Zone,
Yueqing, Wenzhou, Zhejiang Province, P.R. China

Name and address of the manufacturer

Changan Group Co., Ltd.
No. 288 Wei17th Road, Yueqing Economic Development Zone,
Yueqing, Wenzhou, Zhejiang Province, P.R. China

Name and address of the factory

Note: When more than one factory, please report on page 2

Same as manufacturer

Ratings and principal characteristics

See page 2

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

EKM1-63S

Additional information (if necessary may also be reported on page 2)

-

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015

As shown in the Test Report Ref. No. which forms part of this Certificate

180502108SHA-001, -002, -003, -004

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00

Date: 5 June 2018



Signature:

Leif Söderlund

Ratings and principal characteristics $U_n = 230/400V\sim(1P), 400V\sim(2P, 3P, 4P)$ $I_n = 1, 2, 3, 4, 5A, B\text{-}\&C\text{-type}$ $I_n = 6, 10, 16, 20, 25, 32, 40, 50, 63A, B-, C\text{-}\&D\text{-type}$ $I_{cn} = I_{cs} = 6kA (C1\sim C40, B1\sim B40)$ $I_{cn} = I_{cs} = 4,5kA (C50, C63, B50, B63, D6\sim D63)$

Date: 5 June 2018

Signature: *Ce. T. Soderlund*