



Ref. Certif. No.

SE-96782

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Moulded Case Circuit-Breakers
Name and address of the applicant	Zhejiang ETEK Electrical technology Co., Ltd. No. 288 Wei 17th Road, Yueqing Economic Development Zone, Yueqing, Wenzhou, Zhejiang Province, P. R. China
Name and address of the manufacturer	Shanghai Yongji Electrical Co., Ltd. No. 2239 South Jinshi Road, Jinshanwei Town, Jinshan District, Shanghai City, P. R. China
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	Same as manufacturer
Ratings and principal characteristics	Un= 240V~(1P), 415V~(2, 3, 4P), 50/60Hz In= 63, 80, 100, 125A Icu= 10kA, Ics= 7,5kA, Ui= 690V~, Uimp= 6kV Utilization category: A. The fourth pole is identical with phase pole
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	EKM2-125H
Additional information (if necessary may also be reported on page 2)	-
A sample of the product was tested and found to be in conformity with	IEC 60947-2:2016
As shown in the Test Report Ref. No. which forms part of this Certificate	200100011SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

Date: 14 January 2020

intertek

Signature:


Henrik Wikström